



## AUI Department of Environmental Safety & Security Clean Agent Inspection Semi-Annual

Inspector Name:

Date:

Time:

Location of Inspection:

Type of Agent:

- \* Inspections must be conducted on a semi-annual basis
- \* Maintain checklist as documentation of this requirement

Clean Agent Inspection and Test: Semi-Annually	Pass	Fail	N/A	Comments
A. Halon, FM-200, and Novac				
1. Verify that the agent containers have been refilled or replaced as needed. If Halon experiences a loss in weight/quantity >5% or a loss of pressure >10% (Adjusted for temperature.) than the container shall be refilled or replaced,				
2. Ensure the inspector attached the following information - Date of inspection, person performing the inspection, type of agent, gross weight of the container, net weight of agent, and container pressure and temperature.				